



ECO-City

Joint ECO-City developments in Scandinavia and Spain
Supported by the EC CONCERTO Initiative



community presentation

TRONDHEIM


Dagfinn Bell

1
11.10.06

COWI

TRONDHEIM

- Third largest city in Norway:
 - 170 000 inhabitants
 - 341 km²
- 500 km north of Oslo (63.5 °N)
- Cold Nordic climate
- Historic importance
 - founded in 997
- Regional capital and a center for commerce and administration
- Center for technological education and research: NTNU & SINTEF
 - 30 000 students



2
11.10.06

COWI

TRONDHEIM → ECO-City

TRONDHEIM'S MUNICIPAL CLIMATE ACTION PLAN

- Greenhouse gas emissions reduced by 20% from 1999 levels within 2010

Objective related to stationary energy consumption:

- Increase the amount of renewable sources in the energy system
- Reduce energy demand by improved energy efficiency
- Sustainable utilization of local resources for energy production

This shall be accomplished through:

- Municipal energy planning & active use of legislation
- Implementation of energy conservation initiatives
- Giving priority to sustainable use of renewable energy sources
- District heating supply in all parts of the city

3
11.10.06

COWI

ECO-City PARTNERS in TRONDHEIM

- | | | |
|--|--|----------|
| • TRONDHEIM KOMMUNE | | |
| – Municipality of Trondheim | | MUN-NO |
| • TRONDHEIM ENERGIVERK | | |
| – Largest local ESCO (power & district heating) | | UTIL-NO |
| • HEIMDALSGRUPPEN | | |
| – One of the Leading property developers | | BUILD-NO |
| • TOBB | | |
| – Largest housing association in Trondheim | | HOUSE-NO |
| • SVARTLAMOEN BOLIGSTIFTELSE | | |
| – Trust : "ecological experimental area" | | TRUST-NO |
| • SINTEF | | |
| – Large independent research organization | | RTD-NO |
| • COWI | | |
| – Consulting: engineering, environmental science | | IC-NO |

4
11.10.06

COWI

WORK PACKAGES TRONDHEIM COMMUNITY (1)

WP 1.3: COMMUNITY INITIATION

WP 2.3: COMMUNITY ENERGY EFFICIENCY

- 2.3.1 Analysis of Concerto Concepts
- 2.3.2 Polygen cooling concepts
- 2.3.3 Intelligent energy metering, registration and reporting
- 2.3.4 Concepts for seasonal storage of municipal waste

WP 3.3: DEMONSTRATIONS

WP 4.3: COMMUNITY MONITORING

- 4.3.1 Community monitoring system
- 4.3.2 Energy Monitoring

5
11.10.06

COWI

WORK PACKAGES TRONDHEIM COMMUNITY (2)

WP 5.3: TRAINING


- 5.3.1 Benchmarking in private households
- 5.3.2 Eco-lighthouse certification in SME
- 5.3.3 Energy teaching module for elementary schools

WP 6.3: COMMUNITY DISSEMINATION

6
11.10.06

COWI

DIRECT PARTNER ACTIVITIES



7
11.10.06

COWI

WP 2.3 COMMUNITY ENERGY EFFICIENCY (1)

T.2.3.1 Analysis of Concerto concepts

- Analysis of alternative total eco-energy concepts for eco-building projects, both new buildings and renovation projects, applying an integrated approach focussing on energy, emissions, life cycle costs as a whole building approach.
- A set of guidelines will be developed for this whole building approach.

TABLE OF CONTENTS

ANALYSIS OF CONCERTO CONCEPTS	3
1. ENERGY, EMISSIONS, LIFE CYCLE COSTS - A WHOLE BUILDING APPROACH	4
1.1 System boundary.....	4
1.2 Energy	4
1.2.1 Demand side. Building design and technologies.....	4
1.2.2 Supply side. Energy supply systems.....	5
1.3 Emission	7
1.3.1 Emission based on CO ₂	7
1.3.1.1 Petroleumprodukter.....	7
1.3.1.2 Bioprodukter.....	7
1.3.1.3 Elektrisk energi.....	8
1.3.1.4 Fjernvarme.....	9
1.3.2 Emission based on other clima parameters.....	12
1.3.3 Emission based on the energy situation in Norway.....	12
1.4 Economic analysis. Life cycle costs (LCC)	12
1.4.1 Use of energy during the life cycle.....	13
1.4.1.1 Bounded energy.....	13
1.4.1.2 Use of energy during the lifetime.....	13
1.4.2 Life cycle costs	13
1.4.2.1 Costs of buildings.....	14
1.4.2.2 Costs of energy.....	14
1.4.2.3 Costs of emission	14
1.4.3.4 LCC-calculations	14
1.5 Optimizing	14
1.5.1 Optimizing by simple calculations	14
1.5.2 Optimizing by complex simulations	14
2. GUIDELINES	14
2.1 Demand side	15
2.2 Supply side	15
3. GUIDELINES. ECO CITY TRONDHEIM	16
3.1 Svartlamoen	17
3.2 Gravis	19
3.3 Trondheim mun.: Skolehygg, Nursery	19

8
11.10.06

COWI

Whole building approach

DEMAND SIDE, SINTEF - Building and Infrastructure
SUPPLY SIDE, SINTEF - Energy Research
USER BEHAVIOR, SINTEF - Technology and Society


slide by:
Tore Wigenstad

SINTEF

9
11.10.06


COWI

Whole building approach



10
11.10.06

COWI



slide by:
Tore Wigenstad

SINTEF

11
11.10.06

COWI



Trondheim kommune:

ECO-BUILDING REHABILITATION AND LOCAL USE OF BIO MASS IN PUBLIC BUILDINGS

- Improved energy efficiency in renovation projects 17.600 m² public buildings comprising 3 schools.
- Upgrading facades and technical installation to energy efficient systems.
- Local use of biomass and solar heating.

slide by:
Tore Wigenstad

SINTEF

12
11.10.06

COWI



Trondheim kommune:

ECO-BUILDING REHABILITATION AND LOCAL USE OF BIO MASS IN PUBLIC BUILDINGS

Energy Demand	Measures to be adopted in CONCERTO building	Regulation / normal practice* [kWh/m ² yr]	CONCERTO specification [kWh/m ² yr]	Energy savings [%]
Total space heating excl. boiler eff.	Total Building Approach, average in buildings	153	101	34
Other	Average in buildings	67	53	21
Total Energy	Electricity savings	220	154	30

slide by:
Tore Wigenstad
 SINTEF

13
11.10.06

COWI

Heimdalgruppen:

ECO-BUILDING IN NEW HOUSINGS

- Eco-building in new housings 350 dwellings
- Optimised insulation, balanced demand based ventilation, passive solar design, intermediate climate zoning, etc. optimised design.
- Investigation of small scale wind power systems integrated into the building structure in "Town House" at a new ECO-Building site.

slide by:
Tore Wigenstad
 SINTEF

14
11.10.06

COWI

Heimdalgruppen:

ECO-BUILDING IN NEW HOUSINGS

Energy Demand	Measures to be adopted in CONCERTO building	Regulation / normal practice* [kWh/m ² yr]	CONCERTO specification [kWh/m ² yr]	Energy savings [%]
Total space heating excl. boiler efficiency.	Total Building Approach average for Cubic buildings i.e. buildings with low surface/volume ratio.	78	28	64
Other	Average in buildings	93	74	20
Total Energy	Electricity savings	171	102	40

slide by:
Tore Wigenstad


15
11.10.06

COWI

Svartlamoen boligstiftelse:

RENEWABLE ENERGY SUPPLY (RES) AND ECO-BUILDING REHABILITATION IN CITY ECOLOGICAL EXPERIMENTAL AREA

- Eco-building in rehabilitation in City Ecological Experimental Area. 24 dwellings and 3000 m² commercial building.
- Optimised insulation and ventilation, active & passive solar design, intermediate climate zoning, etc. optimised design.
- Local use of biomass and solar heating

slide by:
Tore Wigenstad


16
11.10.06

COWI

Svartlamoen boligstiftelse:

RENEWABLE ENERGY SUPPLY (RES) AND ECO-BUILDING REHABILITATION IN CITY
ECOLOGICAL EXPERIMENTAL AREA

Energy Demand	Measures to be adopted in CONCERTO building	Regulation / normal practice* [kWh/m ² yr]	CONCERTO specification [kWh/m ² yr]	Energy savings [%]
Tot. space heat excl. boiler eff.	Total Building Approach average in buildings	170	117	31
Other	Average in buildings	91	63	31
Total Energy	Electricity savings	273	189	31

slide by:
Tore Wigenstad



17
11.10.06

COWI

slide by:
Tore Wigenstad



DEMAND SIDE

SINTEF - Building and Infrastructure

18
11.10.06

COWI



**From:
State of the art**

**To:
ECO-City**

slide by:
Tore Wigenstad

 SINTEF

EPLEHAGEN - GRANÅS

19
11.10.06

COWI

CASE:



EPLEHAGEN - GRANÅS

slide by:
Tore Wigenstad

 SINTEF

20
11.10.06

COWI

EPLEHAGEN - GRANÅS



21
11.10.06

COWI

EPLEHAGEN - GRANÅS



22
11.10.06

COWI

EPLEHAGEN - GRANÅS



23
11.10.06

COWI



U-verdi

Vindu	: 1,60 W/m ² K
Tak	: 0,15 W/m ² K
Yttervegg	: 0,22 W/m ² K
Gulv	: 0,15 W/m ² K

Balansert ventilasjon
Fjernvarme

24
11.10.06

COWI

EnergiSimulering: Middleilighet

Energibudsjet (netto energibehov) [kWh]

Beskrivelse	Før tiltak	Før tiltak/gulvareal
1. Romoppvarming	3024 kWh	36 kWh/m ²
2. Varmebatterier	772 kWh	9 kWh/m ²
3. Vannoppvarming	2540 kWh	31 kWh/m ²
4. Vifter og pumper	292 kWh	4 kWh/m ²
5. Belysning	1939 kWh	23 kWh/m ²
6. Teknisk utstyr	2424 kWh	29 kWh/m ²
7. Romkjøling	0 kWh	0 kWh/m ²
8. Kjølebatterier	0 kWh	0 kWh/m ²
Totalt energibehov	10991 kWh	132 kWh/m ²

slide by:
Tore Wigenstad



25
11.10.06

COWI

EnergiSimulering:

	EPLEHAGEN AS BUILT	Eco-City tiltakspakke
Yttervegg	U-verdi: 0,22 W/m ² K (200 mm)	0,14 W/m ² K (300 mm)
Yttertak	U-verdi: 0,15 W/m ² K (300 mm)	0,11 W/m ² K (400 mm)
Gulv på grunn	U-verdi: 0,15 W/m ² K (200 mm)	U-verdi: 0,11 W/m ² (250 mm polystyren + 50 mm kantisolasjon)
Vindu	U-verdi: 1,6 W/m ² K (4-15luft-E4))	U-verdi: 1,1 W/m ² K (4E-12arg-4-12arg-4E)
Infiltrasjon	$n_{50} = 2$ oms/h. Infiltrasjon: 0.15 oms/h	$n_{50} = 1$ oms/h. Infiltrasjon: 0.07 oms/h
Ventilasjon	Årsvirkningsgrad for varmegjenvinner på 60 %. SFP-faktor 1.5 kW/m ³ /s	Årsvirkningsgrad for varmegjenvinner på 80 %. SFP-faktor 1.5 kW/m ³ /s. Halv luftmengde natt.
	Ca 145 kWh/m² år	(se neste side...)

slide by:
Tore Wigenstad



26
11.10.06

COWI

EnergiSimulering: "ECO-City Standard"

Energibudsjet (netto energibehov) [kWh]	Før tiltak	Før tiltak/gulvareal
Beskrivelse		
1. Romoppvarming	1555 kWh	19 kWh/m ²
2. Varmebatterier	62 kWh	1 kWh/m ²
3. Vannoppvarming	2540 kWh	31 kWh/m ²
4. Vifter og pumper	211 kWh	3 kWh/m ²
5. Belysning	1939 kWh	23 kWh/m ²
6. Teknisk utstyr	2424 kWh	29 kWh/m ²
7. Romkjøling	0 kWh	0 kWh/m ²
8. Kjølebatterier	0 kWh	0 kWh/m ²
Totalt energibehov	8730 kWh	105 kWh/m ²

slide by:
Tore Wigenstad



27
11.10.06

COWI

slide by:
Tore Wigenstad



SUPPLY SIDE

SINTEF - Energy Research


28
11.10.06

COWI

Supply side A mixture of possibilities...

slide by:
Tore Wigenstad


SINTEF



29
11.10.06

COWI

The challenge Optimal use of local energy resources



slide by:
Tore Wigenstad


SINTEF

30
11.10.06

COWI

- THE MOST ECONOMIC ENERGY SOLUTION DEPENDS ON THE COSTS OF THE INSTALLATION, TOTAL ENERGY-DEMAND AND ENERGY-PRICE.
(all seen in a lifetime perspective)
 - LESS ENERGY DEMAND => RELATIVELY HIGHER ENERGY COSTS EXPRESSED IN CAPITALKOSTS + CONSUMPTION ($\$/\text{kWh}_{\text{TOT}}$)
(in low energy concepts, capital costs is far the major part in the economic LCC-calculations)
 - IN NORWAY, DIRECT ELECTRIC ENERGY IS THE SIMPLEST AND USUALLY THE LESS EXPENCIVE INSTALLATION
(but this energy is far to valuable to use in heating)
 - THE EFFICIENCY OF BIOENERGY DEPENDS ON PROPER COMBUSTION.
(small or distributed stokes and frequent start/stop, tends to contribute to local pollutions)

WP 2.3 COMMUNITY ENERGY EFFICIENCY (2)




T.2.3.2 Polygen cooling concepts

- Analysis and design of large-scale integrated polygen cooling concepts based on state-of-art and emerging technologies.


Eco City

District Heating and Cooling in Trondheim

- TEV Fjernvarme started to deliver district heating (DH) in 1982, and today, it covers 25% of the heating demands in Trondheim.
- The base heat production is from a waste incineration plant.
- In summertime, there is surplus of waste heat in the system. This excess heat is used as the driving energy for absorption chillers in two district cooling plants.
- The first district cooling plant was established at Nedre Elvehavn in 2000.
- The second district cooling plant was established at St. Olavs Hospital in 2004



Absorption chiller
Nedre Elvehavn



Absorption chiller
St. Olavs Hospital



Waste incineration plant
Heimdal Varmesentral

33


11.10.06

COWI

Eco City

Principle of absorption cooling

- The district cooling production plant consists of a heat exchanger for pre-cooling from river water, and an absorption chiller for post cooling with district heat as the driving energy.
- The condenser is cooled by the same river water system, which is used for precooling.
- In the absorption chiller, the mechanical compressor is replaced by a solution circuit with an absorber and a generator. Water is the refrigerant, and lithium bromide – LiBr, is the absorption fluid.
- The lowest district heating temperature is approximately 85°C



34


11.10.06

COWI

Eco City

Natural cooling from river or sea

- At Nedre Elvehavn, which is located 1.5 km from the river mouth, the river water is brackish water
- At St. Olavs Hospital, which is located 4 km further up along the river, the water is fresh water without any influence from the sea water.
- Another opportunity is to use the sea water for cooling purposes. The average monthly sea water temperatures from 80 m depth is quite constant throughout the year.




35
11.10.06

COWI

Eco City

Status of District Cooling in Trondheim

- The first district cooling plant at Nedre Elvehavn was established in october 2000
- The first 1.5 MW absorption chiller was started in june 2001
- Another absorption chiller was built at Nedre Elvehavn in 2003
- The district cooling plant at St. Olavs Hospital with one 3 MW absorption chiller was established in autumn 2004



36
11.10.06


COWI

Eco City

Experiences from the district cooling plant at Nedre Elvehavn

Experiences from five years of operation:

- The maximum cooling demand has been 2.3 MW on 5th july 2005, which was the warmest day that year
- Problems with fouling in the sea water/river water system, especially during the very hot summer in 2002
- Cavitation of river water pump due to clogging of the river water filter
- Poor control of absorption chiller at small capacities



District heating and cooling system at Nedre Elvehavn

37

11.10.06


COWI

Eco City

Experiences from the district cooling plant at St. Olavs Hospital

Experiences after the first year of operation:

- Phase 1 with approximately 50% of the district cooling system is built, but the new hospital buildings has up to now been in test operation
- The average winter cooling demand with 100 000 m² building area in use is about 500 kW
- Up to now, 65% the cooling demand is covered by "free" cooling from river water



District heating and cooling system at St. Olavs Hospital

Chiller plant
District cold - Phase 1
District heat
District cold - Phase 2
River water pipeline

38

11.10.06

COWI


Eco City

Challenges

The specific investments for absorption chillers (Euro/kW cooling capacity) will increase considerably for chillers smaller than 1 000 kW. Compressor chillers are much cheaper at small capacities, but for large capacities, the price difference is only 10% (Upper Figure).

The efficiency for the absorption chillers will decrease considerably at partload operation below 50% (Lower Figure).

Therefore, absorption chillers should be large and they should operate at high capacity.



39

11.10.06

COWI


Eco City

Challenges

One problem is hydraulic restrictions of maximum water flow in the district heating transmission pipeline to the city. The existing transmission pipes are designed for heating demand in winter with forward/return temperatures of 120/70°C, i.e. 50°C temperature difference.

In the summer, the forward water temperature is normally lower, e.g. 90°C, and the temperature decrease in the absorption chiller may be restricted to 10 or 15°C. This small hot water temperature difference and the low COP of the absorption chiller may result in restrictions in hot water supply.

However, a new district heating transmission pipeline is being constructed from the waste incineration plant to the city, and this will probably solve the problem.



40

11.10.06

COWI

T.2.3.3

Intelligent energy metering, registration and reporting

- Development of a cost efficient concept for metering, registration and reporting of energy consumption in private households.
- The concept shall comprise both power and heat consumption and will be developed with a primary focus reducing energy consumption. Cost efficient indirect methods like comfort registration will be evaluated.

Faktorer som påvirker bruken av energi i bygg

- Klima
- Tekniske løsninger
- Kunnskap om hva som påvirker forbruk
- Kunnskap om andres energiforbruk
- Fokus på energibruk i media og blant folk
- Holdning til ressursbruk
- Energipris

Måling gir kunnskap

Får vi forbruket presentert på en god måte kan vi finne ut:

- Hvor, når og hvordan brukes energien
- Energibruk i forhold til areal
- Energibruk i forhold til aktivitet
- Energibruk i forhold til utetemperatur
- Hvor effektivt jeg bruker energien i forhold til andre
- Hva jeg kan gjøre for å redusere mitt energiforbruk

43
11.10.06

COWI

Fjernvarme i borettslag

- Store borettslag med fjernvarme til oppvarming og varmtvann har i dag fellesmåling av fjernvarme.
- Varmen distribueres langs fasader og i felles rør i sjakter slik at måling er komplisert fordi hver leilighet har mange tilførsler
- Betaling skjer sammen med husleie og er fordelt på areal
- Den enkelte beboer mangler forhold til sitt forbruk og har ingen incentiver for nøktern ressursbruk

44
11.10.06

COWI

Måling av strømforbruk i boliger

- I Norge har vi lange tradisjoner med strømmålere i hver bolig
- Mange har god oversikt over hvor mye dem vanligvis betaler til kraftleverandør og nettselskap
- Det er usikkert hvor mange som har et forhold til sitt forbruk i kWh

45
11.10.06

COWI

Concerto aktiviteter

Trondheim og omegn boligbyggelag (Tobb), Trondheim Energiverk AS (TEV), SINTEF og COWI AS skal sammen

- Vurdere metoder for måling av fjernvarmeforbruk i borettslag
- Etablere metoder for presentasjon av energiforbruk til beboere
- Tobb skal i samarbeid med et borettslag med fellesmåling implementere måling av fjernvarme i den enkelte leilighet
- TEV skal i samarbeid med et eller flere borettslag etablere måling med automatisk innhenting av målerdata
- TEV og Tobb skal presentere måleravlesningene til beboerne

46
11.10.06

COWI

T.2.3.4
**Concept for seasonal storage
of municipal waste**

- Analyse and specification of a cost efficient concept for seasonal storage of municipal waste.
- A system description shall be developed, comprising compacting, packaging, transportation and storage.
- Selection of optimal technical solution and logistics will be given particular focus.




47
11.10.06

COWI

Dagens situasjon

En stor del av tilgjengelig energi fra avfallet må kjøles bort om sommeren. Om vinteren må en stor del av energien leveres med andre energibærere.



48
11.10.06

COWI

Framtidens situasjon



Økt energibehov i fjernvarmenettet og økt avfallsmengde

Alt. 1:

TEV kan utvide kapasiteten til å dekke behovet og fortsette å brenne alt avfallet fortløpende som nå. Energiutnyttelse: 74%

Alt. 2 (valgt):

TEV kan bygge større forbrenningsanlegg og ballepresse og lagre avfall fra sommer til vinter. Energiutnyttelse: 87%



49

11.10.06

COWI



**Planlagt utvidelse av Heimdal Varmesentral i Trondheim.
Forventet oppstart sommer 2007.**


50

11.10.06

COWI

Mulige avfallsmengder over året

Til lager fra sommer til vinter: ca. 20.000 tonn/år. 1 tonn avfall tilsvarer ca. 2,4 MWh energi ved forbrenning.



51
11.10.06

COWI

Embattering av ballepresset avfall



52
11.10.06

COWI

Hegstadmoen sommeren 200 med ballepresse og avfall på lager



53

11.10.06

COWI

Status


- Avklarende møter avholdt med alle som ga tilbud i nov. – des. 2005.
- Foreløpig beslutning er å gå videre med forhandlinger med to av tilbyderne
- Nødvendig å utrede evt. problemer med lagring, brannfare, energistabilitet, forbrenningstekniske forhold mm.

54

11.10.06

COWI


WP 3.3 DEMONSTRATIONS



55

11.10.06

COWI




56

11.10.06

COWI

Utvidet fjernvarme



57


11.10.06

COWI

WP 5.3 TRAINING

5.3.3 Energy teaching module for elementary schools

- ENOVA: REGNMAKERNE (www.regnmakerne.no)
- TEV / Trondheim kommune (www.tev.no/skole)



58

11.10.06

COWI

ENERGY BALANCE - TRONDHEIM

ENERGY SUPPLY	Thermal	Electrical
Seasonal storage of waste (90% eff.)	45 000	
Local RES heating (bio and solar)	700	
Total supply	45 700	-
ENERGY DEMAND	Area	Thermal
St. Olav Hospital	200 000	44 600
New eco-buildings	22 000	660
Eco-building rehabilitation, RUE	21 560	(1 470)
Eco-building rehabilitation, RES (conv.)		1 730
Intelligent metering and comfort reg.	53 600	(520)
Total demand	243 560	45 520
		(1 500) 1 120 (110) (1 730) (420) (2 220)

59

11.10.06

COWI

The Mayor's Endorsement

Eco City

Hele 2/3 av strømforbruket i en vanlig norsk husholdning går til oppvarming av bolig og vann. I Norge er vi avhengige av strøm og vi bruker vi mer enn vi produserer selv. Det er på tide å tenke nytt. Derfor er handling rundt hvordan vi kan bruke mindre energi i bygninger viktig. Eco-City er et EU prosjekt med målet å demonstrere innovative integrerte energi løsninger både for brukere og leverandører i tre byområder i Europa. Tudela (Spania), Helsingborg/Helsingør (Sverige/Danmark) og Trondheim (Norge). Deltakerne i Trondheim er Trondheim Kommune, Trondheim Energiverk, Heimdal Eiendomselskap, TOBB, Svartlamon Boligstiftelse, SINTEF og COWI.

Miljøbyen Trondheim står beskrevet i vår kommuneplan. Dialog og samarbeid er en forutsetning for å lykkes i målet om å være en miljøby. Med CONCERTO programmet kan vi samarbeide innad i kommunen, med utbyggere og forskningsinstitusjoner. Vi kan drive framtidssrettet byutvikling i praksis.

Sincerely yours,

Rita Ottervik
Mayor of Trondheim



60

11.10.06

COWI